

Certificate of Conformity

By the product certificate number:

No. 250041RECO01-K-CER

Issued to:

License holder:

Victron Energy B.V.
De Paal 35, 1351 JG Almere, Netherlands

Trademark:



Contract number:

802190

It is certified that the product:

Type of product: Inverter/Charger with UPS functionality

Product Family: Multiplus II - 3phase configuration

Models:	MultiPlus-II 48/8000/110-100 230V	MultiPlus-II 48/10000/140-100 230V	MultiPlus-II 48/15000/200-100 230V
Rated characteristics:			
Rated Power	8 kVA / 6.4 kW	10 kVA / 8 kW	15.0 kVA / 12.0 kW
Rated Voltage		AC input: 187-250 V _{ac} DC input: 38-66 V _{dc} AC output: 220-240 V _{ac} DC output: 48 V _{dc}	
Rated Frequency		50 Hz	
Firmware version	2621552	2627552	2619552
Number of phases		Three Phase ⁽¹⁾ (3L/N/PE)	
Isolation transformer		Yes	

(1) The three-phase system consists of three individual inverters (of the same model) placed in parallel.
(1) See on page 2 installation scheme.

Is in compliance with the standard requirements

- **Technical regulation 3.3.1 – Requirements for energy storage facilities.**
Category A. Energy storage facilities up to 125 kW.
Revision 5. Dated on 15th February 2024.

This certificate is based upon test results offered in the test report No. 2222/0478-K issued on 13th August 2024.

The above-mentioned generating unit is certified according to the SGS internal procedure PROCESO 4 based on the requirements of the UNE-EN ISO / IEC 17065.

This certificate is first issued on 20th February 2025.

This certificate is valid until the 20th February 2030.

Madrid, 20th February 2025.

Daniel Arranz Muñiz
Certification Manager



Installation scheme:

